



Reference Number	Description	Quantity	100 Amp	200 Amp	400 Amp
1	Riser Conduit, Rigid galvanized, Aluminum or Schedule 80 PVC	as needed	1-1/2"	2"	3"
1a	Load Side Conduit, Rigid galvanized, Aluminum, Schedule 80 PVC	as needed	1-1/2"	2"	3"
2a	Line Side Conductor (Must provided minimum of 3' free conductor outside of weather head, 8' at pad mount transformer)	as needed	#2 Copper #1/0 Aluminum	#3/0 Copper #4/0 Aluminum	# 500 MCM Copper #750 MCM Aluminum
2b	Load Side Conductor	as needed	#2 Copper #1/0 Aluminum	#3/0 Copper #4/0 Aluminum	# 500 MCM Copper #750 MCM Aluminum
2c	Neutral Conductor	as needed	#4 Copper # 2 Aluminum	#1/0 Copper #2/0 Aluminum	# 3/0 Copper #4/0 Aluminum
3	Conduit Strap, 2 hole metal strap	as needed (installed 30" apart)	1-1/2"	2"	3"
4	Lag Screw	as needed	As required		
5	Equipment Grounding Conductor	as needed	# 6 Soft Drawn Copper	# 4 Soft Drawn Copper	# 4 Soft Drawn Copper
6	Equipment Grounding Conductor Conduit	as needed	1/2" Schedule 80 PVC		
7	Bushing, PVC or Steel	5	(4) 1-1/2" + (1) 1/2"	(4) 2" + (1) 1/2"	(4) 3" + (1) 1/2"
8	Galvanized Locknuts (Galvanized Rigid, Aluminum Conduit)	10	(8) 1-1/2" + (2) 1/2"	(8) 2" + (2) 1/2"	(8) 3" + (2) 1/2"
8	Galvanized Locknuts (PVC Conduit)	5	(4) 1-1/2" + (1) 1/2"	(4) 2" + (1) 1/2"	(4) 3" + (1) 1/2"
9	Meter Base	1	Lever Bypass UG Feed Supplied by Customer		
10	Ground Rod (Copper Clad Steel installed 6" below final grade)	1	8' x 5/8"	8' x 5/8"	10' x 3/4"
11	Ground Rod Clamp	1	5/8"	5/8"	3/4"
12	Conduit Nipple	1	1-1/2"	2"	3"
13	Weather Proof Disconnect	1	100 Amp	200 Amp	400 Amp
14	Main Breaker or Fuse	1	100 Amp	200 Amp	400 Amp

- NOTES:**
- A. All work should be done in accordance with all national, state, and local codes.
 - B. Line and Load side neutral conductors must be clearly marked with white tape.
 - C. Line side conductors and equipment are from the top of the meter base to the utility point of connection
 - D. Load side conductors and equipment are from the bottom of the meter base to the customers' premises.
 - E. Neutral conductor extends continuously from the neutral lug of the main disconnect through the meter base and on to the weatherhead.
Exception: The neutral conductor is permitted to be separated in the meter base only if the meter base has double lugs for the neutral connection
 - F. The neutral conductor should not automatically reduce two sizes. If there are no 240-volt loads the neutral shall be the same size as the line conductors because it will carry the same current.
 - G. The equipment grounding conductor (EGC) shall terminate at the grounding lug of the meter base and should be connected directly to the ground rod without passing through the disconnect. When a metal conduit nipple is used between the meter base and the main disconnect the green bonding screw must be in place. When a PVC conduit nipple is used between the meter base and the main disconnect it is permissible for the EGC to pass through the disconnect to connect directly to the ground rod. The main disconnect shall be bonded to the EGC and the green bonding screw must be in place.
 - H. Leave (3) feet of free conductor outside the weatherhead on a meter pole and (8) feet on a transformer pole.
 - I. The main disconnect may be a circuit breaker, fused disconnect, or double throw disconnect.
 - J. If PVC conduit is used, schedule 80 must be used from the disconnect to below final grade. This is to include the EGC conduit.
 - K. An insulated bushing is required at the end of each conduit.
 - L. Wood Structure shall consist of at minimum (2) 4"x4" treated wood posts buried to a depth of 3' and backfilled with one bag of concrete mix per post. Back board shall consist of treated 2"x6" lumber fastened to the wood post with lag screws. Steel structures shall consist of at minimum (2) 2" galvanized rigid conduit buried to a depth of 3' and backfilled with one bag of concrete mix per post. Back Board shall consist of 1-5/8" galvanized Unistrut. Steel structures shall be bonded to the EGC.
 - M. If riser is to be installed on MCPU pole, customer must bury conductor to the pole and provide enough conductor, conduit, straps, and weatherhead for MCPU to install on pole.

SPECIAL NOTE: If installing to pad mount transformer, customer should leave 8 Ft. of free conductor for connection at transformer